



Texas Department of State Health Services

PO BOX 149347
 AUSTIN, TEXAS 78714-9347
 1-888-963-7111
 www.dshs.state.tx.us

LABORATORY SERVICES SECTION, MC-1947
 1100 W. 49th St., Austin, Tx. 78756 (512)458-7587

Semivolatiles Organic Analysis Report

Submitter Identification Number: 0840153

GULF COAST WATER AUTHORITY TX CITY
 3630 FM 1765
 TEXAS CITY, TX 77591-3677

Date Reported : 04/10/2012
 Report ID# : 20120410092829AB84696

Lab Sample ID# : AB84696	Water Source :	Date Collected : 03/21/2012 08:03	Conc. Units : µg/L
Sample Priority : NORMAL	Entry Point(s) : EP001	Date Received : 03/22/2012	Method : EPA 525.2
TCEQ ID#(s) : 1216253		Date Analyzed : 03/28/2012	Analyst : DH
		Extraction Date : 03/27/2012	Sample Cond. : Acceptable

Regulated Compounds	Result	Qualifier	Monitored Compounds continued	Result	Qualifier
Alachlor ¹	<0.2		Dimethylphthalate	<2.0	
Atrazine ¹	0.30		Fluorene	<0.20	
Benzo[a]pyrene ¹	<0.02		2,2',3,3',4,4',6-Heptachlorobiphenyl	<0.50	
alpha-Chlordane	<0.2		2,2',4,4',5,6'-Hexachlorobiphenyl	<0.20	
gamma-Chlordane	<0.2		Indeno[1,2,3-cd]pyrene	<0.20	
trans-Nonachlor	<0.2		Metolachlor	<0.20	
Di(2-ethylhexyl) adipate ¹	<0.6		Metribuzin	<0.20	
Di(2-ethylhexyl) phthalate ¹	<0.6		Naphthalene	<0.20	
Heptachlor ¹	<0.04		2,2',3,3',4,5',6,6'-Octachlorobiphenyl	<0.50	
Hexachlorobenzene ¹	<0.1		2,2',3',4,6-Pentachlorobiphenyl	<0.20	
Hexachlorocyclopentadiene ¹	<0.1	*	Phenanthrene	<0.20	
Lindane ¹	<0.02		Prometon	<0.20	*
Methoxychlor ¹	<0.1		Propachlor	<0.20	
Pentachlorophenol ¹	<0.04		Pyrene	<0.20	
Simazine ¹	<0.07		2,2',4,4'-Tetrachlorobiphenyl	<0.20	
Monitored Compounds	Result	Qualifier	2,4,5-Trichlorobiphenyl	<0.20	
Acenaphthene	<0.20		Trifluralin	<0.20	
Acenaphthylene	<0.20				
Aldrin	<0.20		Comments:		
Anthracene	<0.20		* - This analyte has known instability and/or method performance issues and quantitation should be considered approximate.		
Benzo(a)anthracene	<0.20		No duplicate sample was available for a matrix spike analysis (LFM) for this extraction batch for Method 525.2. The test results on this report relate only to the sample identified on this report. The test results for analytes noted(*) meet all TNI (2009 Standard) requirements.		
Benzo[b]fluoranthene	<0.20				
Benzo[g,h,i]perylene	<0.20				
Benzo[k]fluoranthene	<0.20				
Bromacil	<0.20				
Butachlor	<0.20				
Butylbenzylphthalate	<2.0				
2-Chlorobiphenyl	<0.20				
Chrysene	<0.20				
Dibenz[a,h]anthracene	<0.20				
Di-n-butylphthalate	<2.0				
2,3-Dichlorobiphenyl	<0.20				
Dieldrin	<0.20				
Diethylphthalate	<2.0				

Authorized by Team Lead TDUNN on 04/06/2012

