

Stage 2 Drought – MODERATE Water Shortage Conditions*

Triggers and Termination

Triggering and Terminating Criteria				
Initiate	WATER DEMAND for 4 Consecutive Days:	OR WATER SYSTEM for 3 consecutive days experiences:	OR WATER SUPPLY is:	AND GCWA requires municipal customers to reduce GCWA water by 10% or more of current usage
	<ul style="list-style-type: none"> • Equals or exceeds 85% of available contracted surface water supply 	<ul style="list-style-type: none"> • System wells operating at 85% of capacity to augment an inadequate supply of contracted surface water 	<ul style="list-style-type: none"> • Insufficient to meet demand 	
Terminate	When all conditions listed as triggering events have ceased to exist for 7 consecutive days. Authorizing authority shall have discretion to terminate or continue voluntarily.			

* Assumes 4 drought stages:

Stage 1 Mild

Stage 2 Moderate

Stage 3 Severe

Stage 4 Emergency